CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-1496:156 Page 1 of 1

CATEGORY: Control Units (Non High-Rise)

LISTEE: Firecom Inc., 39-27 59th Street, Woodside, NY 11377

Contact: Howard Kogen (718) 899-6100 Fax (718) 899-1932

DESIGN: Model FC610 fire alarm control unit. Power-limited, automatic, manual, coded, noncoded;

local, auxiliary and remote station (Protected Premise Unit), waterflow and sprinkler

supervisory service. System components:

FC610 Control Unit 31025 Bus driver Module 30867 Processor Board

31021, 31022, 31031 610 Analog Addressable Module

LP-864 Line Protector 30952 SIM-232 30996 Network Card 31024 Display Card

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a fire alarm control unit for use with separately listed compatible initiating and

indicating devices.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition. Refer

to listee's Installation Instructions Manual for details.

NOTE: For fire alarm verification feature (delay of fire alarm signal), the maximum

Retard/Rest/Restart period shall not exceed 30 seconds.

XLF: 7165-1288:154

09-29-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 18, 2003 Listing Expires June 30, 2004

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager